

## Annexure C


### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. EMO057

Dated: 21/08/24

It is certified that an inspection team headed by **Dr. A. P. Gupta (E.M.O.)** (Name of officers with designation) from **District Hospital, Mau, U.P.** PHED inspected the **B. R. S. School, Khanpur, Mohammadabad Gohna, Mau, U.P.** (Name & Address of the school) on **21/08/2024** (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **24/08/A** dated **21/08/2024** of **District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Mau** (PHED Lab) certified that the **B. R. S. School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **20/08/2025**.



EMO

Signature with Seal: ... **District Hospital** .....

Mau

Name : **Dr. A. P. Gupta,**

Designation : **E.M.O.,**

Name & Address of the Office / Department: .....

To,


The Manager,

B. R. S. School,

Khanpur, Mau, U.P.

*(Name & Address of the Institution)*

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

  
Principal  
B. R. S. School  
Khanpur-Mau

  
Manager  
B. R. S. SCHOOL  
Khanpur-Mau

## Water Analysis Report



# District Level Water Analysis Laboratory

## UP Jal Nigam (Rural) - Mau

Office Executive Engineer Construction Division

UP Jal Nigam (Rural), Mau- 275101

Report No.: 24/08/A Date: 21.08.2024 No. of Pages: 1

### Customer Details

Name and Address B.R.S. School, Khanpur Mau

### Basic Details of Sample

District	Mau	Block	Ranipur
Habitation	School	Location	Khanpur
Water Source	Submersible	Sample Code	24/08/A
Quantity of Sample	1000 ml (Normal)	S. collected by	Client
Sampling date	20.8.2024	Sample Depositor	Client
Sample Received Date	20.8.2024	Analysis Start Date	20.8.2024
Sampling Method Used	NA	Analysis Completion date	21.08.2024

Temperature (°C) - 23°C

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	4	5	6	7
1	Colour	<5	5	15	IS 3025 (Part 4):2021 Visual Comparison Method
2	Taste	Agreable	Agreable	Agreable	IS 3025(Part 08):2017
3	Odour	Agreable	Agreable	Agreable	IS 3025(Part 04): 2018
4	pH	7.31	6.5	8.5	IS 3025(Part 11): 2017 Electrometric Method
5	Turbidity (NTU)	1.20	1	5	IS 3025 (Part10):2012 Nephelometric Method
6	TDS (mg/l)	180	500	2000	IS 3025(Part 16): 2017 Gravimetric Method
7	Total Hardness (mg/l)	98	200	600	IS 3025(Part 21):2019 EDTA Method
8	Calcium (mg/l)	30.4	75	200	IS 3025(Part 40):2019 EDTA Titrimetric Method
9	Magnesium (mg/l)	20.5	30	100	IS 3025(Part 46):2019 EDTA Method
10	Chloride (mg/l)	20.9	250	1000	IS 3025(Part 32):2019 Argentometric method
11	Alkalinity (mg/l)	94	200	600	IS 3025(Part 23):2019 Potentiometric and indicator Method

**Note:**

1. This certificate refers only to the particular sample(s) submitted for analysis.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
5. Parameters above Permissible Limit are written in bold.
6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
7. Sample is not Collected by Lab.
8. Star (\*) Indicate parameters are not under NABL accreditation.

*Maidul*  
(Report prepared by)



Laboratory Contact detail: email: labmaunath@gamil.com,

\*\* END OF THE ANALYSIS REPORT \*\*

Page No: 1 of 1

*Anurag*  
Principal  
B. R. S. School  
Khanpur-Mau

*Gulab*  
Manager  
B. R. S. SCHOOL  
Khanpur-Mau